
DC Output Modules


T1K-08TD2-1 <---> T1K-16TD2-1 <--->

8-point and 16-point, 12/24 VDC current sourcing DC output module

The 8-point DC module uses a T1K-08B or T1K-08B-1 base, which is purchased separately.


The 16-point DC module uses a T1K-16B or T1K-16B-1 base, which is purchased separately.







Specifications	T1K-08TD2-1	T1K-16TD2-1	
Outputs per Module	8 (source)	16 (source)	
Commons per Module	2 internally connected	4 internally connected	
Output Voltage Range	10.8-26.4 VDC		
Operating Voltage Range	12-24 VDC		
Peak Voltage	50 VDC		
Max. Output Current	1A / pt., 4A / common 1A / pt., 4A / common (subject to derating)		
Max. Leakage Current	15 µA @ 26.4 VDC		
ON Voltage Drop	1.2 VDC @ 1.0 A		
Max. Inrush Current	2A for 100 ms		
OFF to ON Response	< 10 µs		
ON to OFF Response	< 0.5 ms		
Base Power Required	100 mA @ 5 VDC	200 mA @ 5 VDC	
Status Indicators	Logic side		
Error Status Indications(LEDs)	FU1/FU2 ON = fuse 1 or 2 blown	FU1/FU2 ON = fuse 1 or 2 blown FU3/FU4 ON = fuse 3 or 4 blown	
Fuses (User Replaceable) T1K-FUSE-1	2 qty., (6.3 A, 250 V / common) NQ3-6.3 SOC Corp.	4 qty., (6.3 A, 250 V / common) NQ3-6.3 SOC Corp.	
Weight	100 g	140 g	

Equivalent Output Circuit







PLC Overview DL05/06 PLC DL105 DL205 PLC DL305 DL405 PLC Field I/O Software C-more HMIs Other HMI AC Drives Motors Steppers/ Servos Motor Controls Proximity Sensors Photo Limit Switches Encoders Pushbuttons/ Lights Process

Process

Relays/ Timers

TB's & Wiring

Power

Enclosures

Appendix

Part Index

Dimensions and Installation


It is important to understand the installation requirements for your Terminator I/O system. This will ensure that the Terminator I/O products work within their environmental and electrical limits.

Plan for safety


This catalog should never be used as a replacement for the technical data sheet that comes with the products or the T1K-INST-M Installation and I/O Manual (available online at www.automationdirect.com.) The technical data sheet contains information that must be followed. The system installation should comply with all appropriate electrical codes and standards.

Unit dimensions and mounting orientation

Use the following diagrams to make sure the Terminator I/O system can be installed in your application. Terminator I/O units should be mounted horizontally. To ensure proper airflow for cooling purposes, units should not be mounted upside-down. It is important to check the Terminator I/O dimensions against the conditions required for your application. For example, it is recommended to leave 2" depth for ease of access and cable clearance. However, your distance may be greater or less. Also, check the installation guidelines for the recommended cabinet clearances.



Terminator I/O Environmental Specifications				
Ambient Operating Temperature	32°F to 131°F (0°C to 55°C)			
Storage Temperature	-4°F to 158°F (-20°C to 70°C)			
Ambient Humidity	5% to 95% (Non-condensing)			
Atmosphere	No corrosive gases. The level of environmental pollution = 2 (UL 840)			
Vibration Resistance	MIL STD 810C, Method 514.2			
Shock Resistance	MIL STD 810C, Method 516.2			
Voltage Withstand (Dielectric)	1500 VAC, 1 minute			
Insulation Resistance	500 VDC, 10 MΩ			
Noise Immunity	NEMA ICS3-304 Impulse noise 1µs, 1000 V FCC class A RFI (144 MHz, 430 MHz 10 W, 10 cm)			
Agency Approvals	UL, CE, FCC class A, NEC Class 1 Division 2			



1 - 8 0 0 - 6 3 3 - 0 4 0 5 Universial Field I/O


I/O Module Installation

I/O module installation

Terminator I/O modules feature separate terminal bases for easy installation.

To install I/O modules:

- Slide the module into its terminal base (until it clicks into position)
- 2. Hook upper DIN rail tabs over the top of DIN rail, and press the assembly firmly onto the DIN rail.
- 3. Slide the module along the DIN rail until it engages with the adjacent module.



DN-ASB-1 angled mounting bracket







Great for mounting in upper locations




Great for mounting in lower locations





Removing I/O modules is a snap

Grip the locking handle, as shown, and pull gently to eject the I/O module from its base. The module will slide out for easy replacement. This procedure does not apply to network interface modules or power supplies, which have integral bases.



Hot-swappable I/O modules

You can remove I/O modules under power, but exercise caution while doing so. Do not touch the terminals with your hands or any conductive material. Always remove power when possible.

tomation Direct

PLC Overviev

DL05/06 PLC

DL105 PLC

DL205 PLC

DL305 PLC

DL405 PLC

Field I/O

Software

C-more HMIs

Other HMI

AC Drives

Motors

Steppers/ Servos

Motor Controls

Proximity Sensors

Photo Sensors

Limit Switches Encoders

Pushbuttons/ Lights

Process

Relays/ Timers

Comm.

TB's & Wiring

Power

Enclosures

Appendix

Part Index

Power Supplies and Power Requirements

Power supplies

The Terminator I/O product line offers two power supply options: AC or DC. The power supplies are always positioned to the left of the modules to which they supply power. Consult the system configuration examples and the power budgeting example for more information on positioning power supplies.





Power supply specifications

Pow Spec	er Supply cifications	T1K-01AC <>	T1K-01DC <>	
Input V	oltage Range	110/220 VAC	12/24 VDC	
Input Frequency		50/60 Hz	N/A	
Maxim	um Power	50 VA 30 W		
Max. In	rush Current	20 A 10 A		
Insulati Resista		> 10 MΩ @ 500 VDC		
Voltage	Withstand	1 min. @ 1500 VAC between primary, secondary and field ground		
	Voltage	5.25 VDC	5.25 VDC	
5VDC PWR	Current Rating	2000 mA max (see current option note below)	2000 mA max	
	Ripple	5% max.	5% max.	
	Voltage	24 VDC	N/A	
24VDC PWR	Current Rating	300 mA max. (see current option note below)		
	Ripple	10% max.	N/A	
Fuse	use 1 (primary), not replaceable			

Note: 500 mA @ 24 VDC can be achieved by lowering the 5VDC from 2000 mA to 1500 mA .

Power requirements

Module	5VDC	24VDC	Module	5VDC	24VDC	Module	5VDC	24VDC
Interface Modules		DC Output Modules		Analog Input Modules				
T1H-EBC	350	0	T1H-08TDS	200	0	T1F-08AD-1	75	50*
T1H-EBC100	300	0	T1K-08TD1	100	200*	T1F-08AD-2	75	50*
T1H-PBC	530	0	T1K-16TD1	200	400*	T1F-16AD-1	75	50*
T1K-DEVNETS	250	45	T1K-08TD2-1	200	0	T1F-16AD-2	75	50*
T1K-RSSS	250	0	T1K-16TD2-1	200	0	T1F-14THM	60	70*
T1K-MODBUS	300	0	AC Output N	<i>lodules</i>	•	T1F-16RTD	150	0
DC Input Me	odules		T1K-08TA	250	0	Analog Outp	ut Modul	es
T1K-08ND3	35	0	T1K-16TA	450	0	T1F-08DA-1	75	75*
T1K-16ND3	70	0	T1K-08TAS	300	0	T1F-08DA-2	75	75*
AC Input Mo	dules	•	Relay Output Modules		s	T1F-16DA-1	75	150*
T1K-08NA-1	35	0	T1K-08TR	350	0	T1F-16DA-2	75	150*
T1K-16NA-1	70	0	T1K-16TR	700	0	Combination	Analog	Modules
			T1K-08TRS	400	0	T1F-8AD4DA-1	75	60*
			Specialty M	odules	'	T1F-8AD4DA-2	75	70*
			T1H-CTRIO 400 0		* Use either interr	nal or extern	al source	
			* Use either inter for 24VDC	nal or extern	al source	101 24100		

Calculating the power budget

To calculate the power budget, read the available power (current rating) from the Power Supply Specifications table and subtract the power consumed by each module to the right of the power supply. Do not include modules to the right of an additional power supply.

Adding additional power supplies

Each power supply furnishes power only to the network interface and I/O modules to its right. Inserting a second power supply closes the power loop for the power supply to the left, while also powering the modules to its right. Perform a power budget calculation for each power supply in the system.

Power Budget Example					
Module	5VDC	24VDC			
T1K-01AC	+2000 mA	+300 mA			
T1H-EBC	-350 mA	-0 mA			
T1K-16ND3	-70 mA	-0 mA			
T1K-16TD2	-200 mA	-0 mA			
T1F-08AD-1	-75 mA	-50 mA			
Remaining	+1305 mA	+250 mA			

Accessories available for Terminator I/O are listed in the Terminator Field I/O section of the Price List



This power supply powers the network interface module and This power supply powers these three I/O the next two I/O modules modules


7–16 Universial Field I/O 1 - 8 0 0 - 6 3 3 - 0 4 0 5

Expansion I/O Configurations

Expansion cables


T1K-10CBL <--->
T1K-10CBL-1* <--->
Right side to left side expansion cable

The T1K-10CBL(-1) connects the right side of an I/O base to the left side of the next I/O base. A maximum of two T1K-10CBL(-1) cables can be used per expansion system.




T1K-05CBL-LL <---> T1K-05CBL-LL-1* <---> Left side to left side expansion cable

The T1K-05CBL-LL(-1) connects the left side of an I/O base to the left side of the next I/O base. Only one T1K-05CBL-LL (-1) cable can be used per expansion system and must be used with a T1K-05CBL-RR(-1) cable. This cable cannot be connected to the left side of the network interface base.



T1K-05CBL-RR <---> T1K-05CBL-RR-1* <---> Right side to right side expansion cable


The T1K-05CBL-RR(-1) connects the right side of an I/O base to the right side of the next I/O base. A maximum of one T1K-05CBL-RR(-1) cable can be used per expansion system. Note: When this cable is used, the expansion I/O assignments are from right to left (reversed).



*Note: The (-1) versions of the expansion cables pass 24 VDC through on an isolated wire. (All cables pass the 5 VDC base power.) Any local expansion DC input module configured for "internal power" (current sourcing) must either have a power supply preceding it on the same base or, have a (-1) version cable pass 24 VDC from a power supply on the preceding base.


Using two T1K-10CBL expansion cables

In the system below, power supplies can be used anywhere.




Using T1K-10CBL expansion cable and T1K-05CBL-RR expansion cable

Power supplies can be used anywhere in the first two bases, but not in the last expansion base.




Using T1K-05CBL-RR expansion cable and T1K-05CBL-LL expansion cable

Power supplies can be used anywhere in the first and third bases, but not in the second base.



Using T1K-05CBL-RR expansion cable

Power supplies can be used anywhere in the first base, but not in the second base.



PLC Overview

DL05/06
PLC

DL105 PLC DL205 PLC

DL305

DL405 PLC

Field I/O

Software

C-more

Other HMI

AC Drives

Motors

Steppers/ Servos

Motor Controls

Proximity Sensors

Photo

Limit Switches

Encoders

Pushbuttons/ Lights

Process

Relays/ Timers

Comm.

TB's & Wiring

Power

Enclosures

Appendix

Part Index

Field Device Wiring and Power Options

Terminal base specifications

Terminator I/O terminal bases are available in screw clamp and spring clamp versions for both half-size and full-size modules. Hot stamp silkscreen labeling is used for numbering I/O points, commons, and all power terminals.


Terminal Base Specifications				
Terminal Type	Screw type	Spring clamp		
Recommended Torque	1.77-3.54 lb-in (0.2 - 0.4 Nm)	n/a		
Wire Gauge	Solid: 25-12 AWG Stranded: 26-12 AWG	Solid: 25-14 AWG Stranded: 26-14 AWG		

Field device wiring options

Power your DC input devices from the integrated 24 VDC power supply bus. T1K-08ND3 and T1K-16ND3 DC input modules include jumpers for selecting the internal 24 VDC power supply available for 2- and 3-wire field devices. Clearly labeled triple stack terminals make it easy to wire 2- and 3-wire devices ensuring clean wiring with only one wire per termination.

External user supplied 24 VDC power, or auxiliary 24 VDC terminals from T1K-01AC, can be easily applied directly to one end of the terminal rows and jumpered across each base in the system.

This is a convenient solution for powering analog I/O and discrete DC output devices whose modules do not have direct access to the internal bussed 24 VDC. If current consumption increases, simply add additional T1K-01AC power supplies into the system.



Hot-swap feature

The hot-swap feature allows Terminator I/O modules to be replaced while system power is on. Be careful not to touch the terminals with your hands or other conductive material to avoid the risk of personal injury or equipment damage. Always remove power if it is equally convenient to do so.

Note: Before hot-swapping analog or DC output modules in a Terminator I/O system, make sure that each of the analog and DC output module's 24 VDC and 0 VDC base terminals are wired directly to the external power supply individually. If the external 24 VDC and 0 VDC is jumpered from base to base in a daisy chain fashion, and an analog or DC output module is removed from its base, the risk of disconnecting the external 24 VDC and 0 VDC to the subsequent I/O modules exists.

7–18 1 - 8 0 0 - 6 3 3 - 0 4 0 5 Universial Field I/O